



CLIFF'S FIRE EXTINGUISHER CO., INC.

311 Bell Park Drive, Woodstock, GA 30188
Phone: 770-591-5271 Fax: 770-591-4033



Customer: **Towne Lake Community Church**
Billing Address: **132 N. Medical Parkway, Woodstock, GA 30189**
Site Address: **Towne Lake Community Church, 132 N. Medical Parkway, Woodstock, GA 30189 (Cherokee)**

05/11/2020

Re: Letter of Certification

To Whom It May Concern:

Cliff's Fire Extinguisher Co, Inc. completed the following work:

Calibrated two water gauges and replace two Cleared blocked inspectors test line Performed 5-year internal inspections Placed missing heads in head box Verified state of heads in atrium Tightened up 6-inch unflange to stop leak Cleaned and tightened 4-inch coupling Placed viking head wrench in Riser room Installed hydraulic placards Dusted heads and adjusted plates throughout. Installed Breakaway lock on preschool riser control valve

The work was supervised by the signatory below. The work performed by Cliff's Fire Extinguisher Co., Inc was done in accordance with NFPA 25 2011. The system was returned to service.

Sincerely,

Matt Gore

Cliff's Fire Extinguisher Co., Inc.

WO 23250